

Advice on using the Energy Bridge in a switchboard

Disclaimer

The material in this document has been prepared by Sungrow Australia Group Pty. Ltd. ABN 76 168 258 679 and is intended as a guideline to assist solar installers for troubleshooting. It is not a statement or advice on any of the Electrical or Solar Industry standards or guidelines. Please observe all OH&S regulations when working on Sungrow equipment.

Overview:

Sungrow are often asked whether the new Energy Bridge can be used as a main switch.

Sungrow's official response is:

Our interpretation of AS/NZS3000-2018 (2.3.2.2.1) indicates that the energy bridge does not comply with the it being as a main switch under this clause.

Installer's interpretation:

Sungrow understands that the standards are 'interpretive' and that the installer on the job may interpret this clause differently.

The final decision is therefore up to the installer and how he/she interprets the relevant standards.