

## The compliance declaration of Regulatory Changes for Smarter Homes in South Australia

Conformation Letter for Sungrow inverters:

Single-phase: SG2K-S SG2K5-S SG3K-S SG3K-D SG5K-D SG8K-D

Three-phase: SG5KTL-MT SG10KTL-MT SG12KTL-M SG15KTL-M SG20KTL-M  
SG30CX SG50CX SG110CX

Hybrid inverter: SH5K-30 SH5.0/8.0/10RT

Hereby confirms that the Sungrow inverters meet the requirements specified in  
“Department for Energy and Mining Preparatory Plan Regulatory Changes for Smarter  
Homes” .

1. *Remote disconnection and reconnection requirement.*

-----Sungrow inverters already owns DRM0 required by AS4777.2:2015 so that meets  
this requirement.

2. *Low voltage ride-through requirement*

-----Sungrow inverters have passed the test according to AMEO's *Short Duration  
Undervoltage Response Test* and obtained the test report issued by a third-party testing  
facility approved by AMEO.

3. *Dynamic export limits requirement*

-----Sungrow inverters are equipped with internet capability and an onboard  
communications port.

Thank you,



Jerry

Global Channel & Solution Director  
Sungrow Power Supply Co., Ltd.  
25th Aug 2020