

Label / Sign Information after Battery Installation

(V1.0, 201806)

According to the requirements of the CEC (Clean Energy Council) standard, after the battery installation, the following two labels should be pasted on the specified location.

Label 1 Sign for energy storage adjacent to the meter box and main switchboard



Figure 1 ES sign example in CEC standard

Label 2 Sign for battery system required on enclosures, doors to battery rooms / fenced off section of a larger room. The sign shall be adjacent to the battery system isolator – or an additional sign shall be installed.




Figure 2 Battery supply sign example in CEC standard

The specified parameters for SBP4K8 are as follows.

- Battery UN Number: UN 3480 (Lithium ion)
- Battery IP grade: IP55
- Short circuit current: 300 A
- Maximum DC voltage: 58.1 V