

Sungrow Inverter and Compatible Accessories

Disclaimer

The material in this document has been prepared by Sungrow Australia Group Pty. Ltd. ABN 76 168 258 679 and is intended as a guideline to assist solar installers for troubleshooting. It is not a statement or advice on any of the Electrical or Solar Industry standards or guidelines. Please observe all OH&S regulations when working on Sungrow equipment.

This document outlines the compatibility of the Sungrow WiFi dongles, smart meters, logger and all the Sungrow inverter models. When commission the inverter with the meters, make sure the firmware of the inverter/ dongle/ logger has been updated to the latest version.

| Inverter Model | Type | Wifi | Ethernet | Meter | Logger/M4 |
|---|------------------------|---------------------|-------------|--|---------------------|
| SG3/5/8K-D Premium | Single Phase PV | V31 | E-Net | S100 DTSU666 | EyeM4A |
| SG5/10/15/20KTL-MT | Three Phase PV | V31 | E-Net | T65 (Discontinued) DTSU666 DTSD1352 | EyeM4 Logger1000 |
| SG5.0/7.0/10/15/20RT | Three Phase PV | WiNet V31 | WiNet | DTSU666 DTSD1352 | EyeM4 Logger1000 |
| SH5.0/6.0RS | Single Phase Hybrid | WiNet-S | WiNet-S | S100 DTSU666 | EyeM4 |
| SG2.0RS-S SG3.0/5.0/8.0RS SG5.0RS-ADA | Single Phase PV | WiNet-S | WiNet-S | S100 DTSU666 | EyeM4 Logger1000 |
| SH5K-20 | Single Phase Hybrid | V25 | Inbuilt LAN | S100 DTSU666 | NA |
| SH5K-30 | Single Phase Hybrid | V31 | Inbuilt LAN | S100 DTSU666 | EyeM4 |
| SH5/10RT | Three Phase Hybrid | V31 WiNet | Inbuilt LAN | T65 (Discontinued) DTSU666 DTSD1352 | EyeM4 Logger1000 |
| SG30/50/110CX | Three Phase PV | EyeM4 Logger1000 | Logger1000 | DTSD1352 DTSU666 (SG30CX ONLY) | EyeM4 Logger1000 |

If the issue persists after following above procedures, please take photos testing on site and contact Sungrow Service Department on 1800 786 476 or email to service@sungrowpower.com.au, Monday- Friday 9am - 5pm (AEDT).